

**661—210.5(100) Smoke detectors—new and existing construction.**

**210.5(1) *New construction.*** All multiple-unit residential buildings and single-family dwellings which are constructed after July 1, 1991, shall include the installation of smoke alarms meeting the requirements of rule 661—210.3(100).

**210.5(2) *Existing construction.*** All existing single-family units and multiple-unit residential buildings shall be equipped with smoke alarms or detectors as required in paragraph 210.3(12) “a.”  
[ARC 8550B, IAB 2/24/10, effective 4/1/10; ARC 5254C, IAB 11/4/20, effective 12/9/20]